

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2008010302294534

Valid from: Nov.17,2022

Valid until: Nov.16,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT	SOCOMEK China Co.,Ltd. Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	SOCOMEK S.A.S 1, Rue De Westhouse 67230 Benfeld Cedex France
NAME AND LOCATION OF THE FACTORY	Zhejiang Socomec Co.,Ltd. Heshenqiao Industrial Zone Puqi Yueqing Zhejiang P.R.China (Zhejiang KEDU Electric Manufacture CO.,LTD.)
PRODUCT NAME, MODEL AND SPECIFICATION	load break switch SIRCO M 63, SIRCO M 80,SIRCO M CD100 : Ui : 800V; Uimp:8kV; Ue: AC415V; Ith: 63A,80A,100A; Ie: 63A(SIRCO M 63 AC-23A),80A (SIRCO M 80 AC-23A,SIRCO M CD100 AC-23A),100A(SIRCO M CD100 AC-22A); Icw: 1.5kA/1s; Icm(Peak): 2.1kA; Utilization Category: AC-23A(63A,80A);AC-22A(100A); Poles: 3P;4P with additional Pole
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.3-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.10,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

杨志刚

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE