中国国家强制性产品认证证书

证书编号：2024010305641593

认证委托人名称及地址
法国溯高美电气公司
1, Rue De Westhouse 67230 Benfeld Cedex France

生产者名称及地址
法国溯高美电气公司
1, Rue De Westhouse 67230 Benfeld Cedex France

生产企业名称及地址
法国溯高美电气公司
1, Rue De Westhouse 67230 Benfeld Cedex France

产品名称和系列、型号、规格
转换开关电器
ATyS 2000A, ATyS d 2000A, ATyS t 2000A, ATyS g 2000A, ATyS p 2000A, ATyS A 2000A, ATyS C 2000A,
ATyS 2500A, ATyS d 2500A, ATyS t 2500A, ATyS g 2500A, ATyS p 2500A, ATyS A 2500A, ATyS C 2500A,
ATyS 3200A, ATyS d 3200A, ATyS t 3200A, ATyS g 3200A, ATyS p 3200A, ATyS A 3200A, ATyS C 3200A;
详见附页

产品标准和技术要求
GB/T 14048.11-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2024 年 06 月 12 日　　有效期至：2029 年 06 月 11 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010305641593

ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A, ATyS A 2000A,ATyS C 2000A,ATyS 2500A,ATyS d 2500A,ATyS t 2500A,ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A,ATyS 3200A,ATyS d 3200A,ATyS t3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A

Ui:1000V (主回路),300V (控制回路);

Uimp：12kV (主回路),4kV (控制回路);

Ue:AC415V；

ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A, ATyS A 2000A,ATyS C 2000A：

Ith:2000A；

Ie:2000A (AC-32B),1600A (AC-33iB),1250A (AC-33B);

ATyS 2500A,ATyS d 2500A,ATyS t 2500A,ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A：

Ith:2500A；

Ie:2500A (AC-31B),2000A (AC-32B,AC-33iB),1250A (AC-33B);

ATyS 3200A,ATyS d 3200A,ATyS t 3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A：

Ith:3200A；

Ie:3200A (AC-31B);

Icw:50kA/60ms, Icm (峰值)：105kA；

电器级别：PC 级;

转换方式：ATSE,RTSE;

极数:3P,4P

本页为证书附页，应与证书主页同时使用。

中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010305641593

NAME AND ADDRESS OF THE APPLICANT
SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND ADDRESS OF THE MANUFACTURER
SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY
SOCOMEC S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

PRODUCT NAME,MODEL AND SPECIFICATION
Transfer Switching Equipment
ATyS 2000A,ATyS d 2000A,ATyS t2000A,ATyS g 2000A,ATyS p 2000A,ATyS A 2000A,ATyS C 2000A,ATyS 2500A,ATyS d 2500A,ATyS t2500A,ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A,ATyS 3200A,ATyS d 3200A,ATyS t3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A ; See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS
GB/T 14048.11-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2024).

Valid from : Jun.12,2024 Valid until: Jun.11,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

http://www.cqc.com.cn Building 5, Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010305641593

ATyS 2000A,ATyS d 2000A,ATyS t2000A,ATyS g 2000A,ATyS p 2000A,ATyS A 2000A,ATyS C 2000A,ATyS 2500A,ATyS d 2500A,ATyS t2500A,ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A,ATyS 3200A,ATyS d 3200A,ATyS t3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A;
Ui:1000V (main circuit), 300V (controller);
Uimp: 12kV (main circuit), 4kV (controller);
Ue:AC415V;
ATyS 2000A,ATyS d 2000A,ATyS t2000A,ATyS g 2000A,ATyS p 2000A,ATyS A 2000A,ATyS C 2000A:
Ith:2000A;
Ie:2000A (AC-32B), 1600A (AC-33iB), 1250A (AC-33B);
ATyS 2500A,ATyS d 2500A,ATyS t2500A,ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A:
Ith:2500A;
Ie:2500A (AC-31B), 2000A (AC-32B,AC-33iB), 1250A (AC-33B);
ATyS 3200A,ATyS d 3200A,ATyS t3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A:
Ith:3200A;
Ie:3200A (AC-31B);
Icw:50kA/60ms, Icm (peak value): 105kA;
PC class com.cqc.cms.component.word.CertiAnnexDataModelATSE,RTSE; 3P, 4P

This page is attached to the certificate and should be used at the same time as the certificate page.

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE