

IEC**IECEE**

TM

Ref. Certif. No.

CN55101

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOMEC S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMEC S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMEC S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 12kV;Ui: 1000V;Ith: 630A(FUSERBLOC 630A),800A(FUSERBLOC 800A);
Ue: AC690V;Ie: 630A(FUSERBLOC 630A),800A(FUSERBLOC 800A);
Utilization category: AC-22B;Number of poles:2P,3P,4P;Iq: 80kA;Rated
frequency :50/60Hz

Trademark / Brand (if any)

SOCOMEC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC 630A,FUSERBLOC 800A;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-099767

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.09,2021

Signature:

Xie ZhaoXu

**CB 0065322**