



TYPE APPROVAL CERTIFICATE



N. ELE094817CS

This is to certify that the product below is found to be in compliance with the applicable requirements of the RINA type approval system.

<i>Description</i>	Switch-disconnector-fuse	
<i>Type</i>	FUSERBLOC CD FUSERBLOC BS	
<i>Applicant</i>	SOCOMECS.A. 1 Rue de Westhouse F 67235 Benfeld Cedex France	
<i>Manufacturing Place</i>	SOCOMECS.A. 1 Rue de Westhouse F 67235 Benfeld Cedex FRANCE	SOCIETE TIMELEC SARL Zone Industrielle Chebeda Route de Fouchana Naasse 1135 NASSEN GOVERNORATDE BEN AROUS TUNISIA
<i>Testing Standards</i>	RINA Rules Part C, Ch.2, Sec. 8	

Issued in **Genova** on **December 07, 2018**

This certificate is valid until **December 07, 2023**

Valerio Bonanni

RINA Services S.p.A.

Valerio Bonanni



TYPE APPROVAL CERTIFICATE



N. ELE094817CS

Switch-disconnectors-fuse type:

FUSERBLOC BS 32A, BS 63A, BS 80A, BS 100A, BS 160A, BS 200A, BS 250A, BS 400A.

FUSERBLOC CD 10X38, CD 14X51, CD 32A BS A1, 14X51 50A, 22X58 100A, 22X58 125A, 00C 63A, 00 125A, 00 160A, 0 160A, 250A size 1, 400A size 2.

Technical data:

Rated insulation voltage (Ui): 800V; Rated frequency: 50/60 Hz; Ambient air temperature: 45°C; Thermal current (Ith);
Rated operational voltage (Ue): 415V, 500V or 690V; Rated operational current (Ie); Utilization category: AC-23A.

FUSERBLOC BS 32A	Ue (V)	Ith (A)	Ie (A)
	690	32	32
FUSERBLOC BS 63A	Ue (V)	Ith (A)	Ie (A)
	690	63	63
FUSERBLOC BS 80A	Ue (V)	Ith (A)	Ie (A)
	690	80	80
FUSERBLOC BS 100A	Ue (V)	Ith (A)	Ie (A)
	690	100	100
FUSERBLOC BS 160A	Ue (V)	Ith (A)	Ie (A)
	500	160	160
FUSERBLOC BS 200A	Ue (V)	Ith (A)	Ie (A)
	415	200	200
FUSERBLOC BS 250A	Ue (V)	Ith (A)	Ie (A)
	690	250	250
FUSERBLOC BS 400A	Ue (V)	Ith (A)	Ie (A)
	415	400	400

Technical data:

Rated insulation voltage (Ui): 800V; Rated frequency: 50/60 Hz; Ambient air temperature: 45°C; Thermal current (Ith);
Rated operational voltage (Ue): 415V, 690V; Rated operational current (Ie); Utilization category: AC-23A.

FUSERBLOC CD 10x38	Ue (V)	Ith (A)	Ie (A)
	415	32	32
	690	32	32
FUSERBLOC CD 14X51	Ue (V)	Ith (A)	Ie (A)
	415	32	32
	690	32	32
FUSERBLOC CD 32A BS A1	Ue (V)	Ith (A)	Ie (A)
	415	32	32
	690	32	32



TYPE APPROVAL CERTIFICATE



N. ELE094817CS

Technical data:

Rated insulation voltage (Ui): 750V; Rated frequency: 50/60 Hz ; Ambient air temperature: 45°C; Thermal current (Ith);
Rated operational voltage (Ue): 500V, 690V; Rated operational current (Ie); Utilization category: AC-23A.

FUSERBLOC 14x51 50A	Ue (V)	Ith (A)	Ie (A)
	690	50	50
FUSERBLOC 22X58 100A	Ue (V)	Ith (A)	Ie (A)
	690	100	100
FUSERBLOC 22x58 125A	Ue (V)	Ith (A)	Ie (A)
	500	125	125
	690	125	100
FUSERBLOC 00C 63A	Ue (V)	Ith (A)	Ie (A)
	690	63	63
FUSERBLOC 00 125A	Ue (V)	Ith (A)	Ie (A)
	690	125	125
FUSERBLOC 00 160A	Ue (V)	Ith (A)	Ie (A)
	500	160	160
	690	160	125
FUSERBLOC 0 160A	Ue (V)	Ith (A)	Ie (A)
	500	160	160
FUSERBLOC 250A Size1	Ue (V)	Ith (A)	Ie (A)
	690	250	250

Technical data:

Rated insulation voltage (Ui): 800V; Rated frequency: 50/60 Hz; Ambient air temperature: 45°C; Thermal current (Ith) ;
Rated operational voltage (Ue): 400V ; Rated operational current (Ie); Utilization category: AC-23A.

FUSERBLOC 400A size 2	Ue (V)	Ith (A)	Ie (A)
	400	400	400

Documents

KEMA Certificates n° 2006101.10, n° 2006101.11, n° 2006101.12, n° 2006101.13, n° 2006101.14, n° 2006101.15, n° 2006101.16, n° 2006101.17.

KEMA Certificates n° 98.4418.01, n° 98.4418.02, n° 98.4418.03, n° 2006101.01, n° 2006101.02, n° 2006101.03, n° 2006101.04, n° 2006101.05, n° 2006101.06, n° 2006101.07, n° 2006101.08, n° 2006101.09.

Laboratoire D'Essais Electriques Pierre Siat Test Report n° TR 9185 CPR for the vibration tests.