

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010305501941

Valid from: Apr.16,2021

Valid until: Apr.16,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	SOCOMECS.A 1, Rue De Westhouse 67230 Benfeld Cedex France
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	SOCOMECS.A 1, Rue De Westhouse 67230 Benfeld Cedex France
NAME AND LOCATION OF THE FACTORY	SOCIETE TIMELEC SARL ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia
PRODUCT NAME, MODEL AND SPECIFICATION	Automatic Transfer Switching Equipment ATyS□□ ; See the appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.11-2016
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0031492

产品认证证书

II型自愿认证

附 录

证书编号: CQC2011010305501941

第 1 页 共 2 页

纸 号: 31492

ATyS□□;

Ui: 800V(主回路), 300V(控制回路); Uimp: 6kV(主回路), ATyS dM: 4kV, ATyS pM、ATyS gM、ATyS tM、ATyS cM: 2.5kV (控制回路);

Ith: 160A; Ue: 240VAC(ATyS dM 2P, ATyS gM 2P), 138/240VAC(ATyS dM 4P, ATyS gM 4P, ATyS pM 4P), 240/415VAC(ATyS dM 4P, ATyS gM 4P, ATyS tM 4P, ATyS cM 4P, ATyS pM 4P);

ATyS dM、ATyS pM、ATyS cM: Ie: AC-32B, AC-33iB: 40, 63, 80, 100, 125, 160A; AC-33B: 40, 63, 80, 100, 125A;

AC-32A: 40, 63, 80, 100A;

ATyS gM: Ie: 2P: AC-32B, AC-33iB: 40, 63, 80, 100, 125, 160A;

AC-33B: 40, 63, 80, 100, 125A;

AC-32A: 40, 63, 80, 100A;

Ie: 4P: AC-32B, AC-33iB: 20, 32, 40, 63, 80, 100, 125, 160A;

AC-33B: 20, 32, 40, 63, 80, 100, 125A;

AC-32A: 20, 32, 40, 63, 80, 100A;

ATyS tM: Ie: AC-32B, AC-33iB: 20, 32, 40, 63, 80, 100, 125, 160A;

AC-33B: 20, 32, 40, 63, 80, 100, 125A;

AC-32A: 20, 32, 40, 63, 80, 100A;

使用类别: AC-32A、AC-32B、AC-33iB、AC-33B;

Iq: 160A: 40kA; 125A、100A、80A、63A、40A、32A、20A: 50kA;

电器级别: PC 级; 转换方式: ATSE, RTSE;

极数: 2P(ATyS dM, ATyS gM), 4P(ATyS dM, ATyS gM, ATyS tM, ATyS cM, ATyS pM);

注: 此附录与证书同时使用时有效。



中国质量认证中心

产品认证证书

II型自愿认证

附 录

证书编号: CQC2011010305501941

第 2 页 共 2 页

纸 号: 31492

型号解释:

ATyS □ □
① ② ③

- ① 企业产品系列名称: 自动(遥控)转换开关
- ② 控制类型: dM 是 RTSE, gM、tM、cM 和 pM 是 ATSE, 控制器 gM 和 tM 无 LCD, cM 和 pM 有 LCD。
- ③ 电流规格: 20A, 32A, 40A, 63A, 80A, 100A, 125A, 160A。

注: 此附录与证书同时使用时有效。



中国质量认证中心