

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010302862502

Valid from: Apr.16,2021

Valid until: Apr.16,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	SOCOMECHINA Co.,Ltd. Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	SOCOMECH S.A 1, Rue De Westhouse 67230 Benfeld Cedex France
NAME AND LOCATION OF THE FACTORY	SOCOMECH S.A 1, Rue De Westhouse 67230 Benfeld Cedex France
PRODUCT NAME, MODEL AND SPECIFICATION	Switch-disconnector INOSYS LBS 800A,INOSYS LBS 1000A,INOSYS LBS 1250A;See the appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.3-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0031493

产品认证证书

II型自愿认证

附 录

证书编号: CQC2016010302862502

第 1 页 共 1 页

纸 号: 31493

INOSYS LBS 800A, INOSYS LBS 1000A, INOSYS LBS 1250A;

额定冲击耐受电压 (U_{imp}): 12kV;

额定绝缘电压 (U_i): 1500V;

约定发热电流 (I_{th}): 800A, 1000A, 1250A;

额定工作电压 (U_e): DC1000V;

额定工作电流 (I_e): 800A, 1000A, 1250A;

额定短时耐受电流 (I_{cw}): 8kA/1s;


额定短路接通能力 (I_{cm}): 10kA;

使用类别: DC-21B;

极数: 4P 外形, 见直流接线方式;

直流接线方式:

4P 外形:



注: 此附录与证书同时使用时有效。



中国质量认证中心